

SYNTHESIS DOCUMENT
PRODUCTS CONFORMITY ASSESSMENT

1 SCOPE OF THIS DOCUMENT

The present document constitutes the synthesis of the APAVE report n° 8466641-001-1 which gives the details of inspections and tests achieved on the product.

The test results are based on following AUGIER qualification report :

6050102-QTP IEC-rev5, 6050112-QTR_2-5kVA IEC-rev4, 6050122-QTR_10kVA IEC-rev3 and 6050132-QTR--_30kVA IEC-rev4.

2 CONCERNED PRODUCT Single phase constant current regulator

- | | | | |
|-----------|------------|--------------------------|---------------------------------------------------|
| • Brand : | AUGIER | • Voltage : | 220, 230, 240, 380, 400,
415 Vac |
| • Make : | AUGIER SAS | • Power rating : | 1 – 2,5 – 5 – 7,5 – 10 – 15
– 20 – 25 – 30 kVA |
| • Model : | DIAM 4100 | • Nominal current : | 6,6 A |
| | | • Max brilliancy steps : | 8 |

3 SCOPE OF THE MISSION (to see details in report)

Conformity Assessment of the product and its technical file to the following documents :

⇒ IEC 61822, ed: 2009, ICAO annexe 14.

⇒ SPECIFICATION AENA : PPT/002-05/13 (2013-02-22)

CONCLUSION OF THE REPORT

The conclusion of the report shows that the examined product is in compliance with the prescriptions of the reference documents.

Tassin, 2016/09/27

Technical manager of the testing Laboratory

Document original immatériel



Limit of validity of this document : 2021/09/26

Xavier SCHMITT

This document is not a report established under the title of a Notified body, it is a synthesis of the mission achieved by APAVE and only the complete French report maybe used as reference. It doesn't substitute itself to the DECLARATION OF CONFORMITY issued by the manufacturer, according the market regulation of the EUROPEAN UNION and cannot be use as a guarantee of the production conformity to the type.
Its reproduction is only allowed as a complete photographic facsimile